

CITY OF VENTURA

FIRE DEPARTMENT

MEDIA RELEASE

Date: 03-23-2021
Incident Number: 21-0024956
Information Contact: Thomas Hoffman, Captain
Incident Type: Structure Fire
Date/Time of Incident: 03-23-2021 @1119
Incident Location: 1000 Block of Vista Del Mar Pl.
Cause: Undetermined
Injuries: None
Number of Personnel: 20
Fire Equipment: 5 Engines, 1 Medic truck, 1 Battalion Chief and 1 Investigator
Agencies Involved: Ventura City Fire

Narrative: On the above date and time, Ventura City Fire was dispatched to a reported commercial alarm. En route, the incident was upgraded to a structure fire. On first unit arrival, crews located a small active fire in a ground floor apartment with sprinklers activated. Fire sprinklers extinguished the fire but the apartment was changed with smoke. Crews made entry and ventilated the unit as other fire units controlled electricity and water flow. Fire damage was limited to cabinetry and construction materials in the unit kitchen. All adjoining units were investigated with no fire spread found.

Ventura City Fire Investigator was on scene to determine possible causes. Water damage throughout the unit was extensive and on site restoration crews were able to make repairs once the investigation was complete. No injuries were reported, the building was returned to site managers.

Due to HIPAA we are prevented from disclosing an individual's protected health information (PHI). We may not release information regarding patient's names, DOB, address, SS# or medical status.