

Structure Fire

 Print

[Share](#)

[RSS](#)

08/10/2015

MEDIA RELEASE

Incident Number: 15-0053027

Information Contact: Tony Hill, Battalion Chief

Incident Type: Structure Fire

Date/Time of Incident: August 10, 2015 / 10:52 AM

Incident Location: 300 Block of Lynnbrook Avenue

Cause: Electrical

Injuries: None

Number of Personnel: 14

Fire Equipment: 3 Paramedic Engines, 1 Support, 1 Command

Agencies Involved: Ventura City Fire

Narrative: On the above date and time Ventura City Fire Department was dispatched to a reported structure fire in the 300 block of Lynnbrook Ave. The first arriving fire crew discovered light smoke dispersed throughout the house. A small fire was discovered in a garage wall near an electrical outlet. Firefighters shut down the electricity to the outlet and extinguished the fire in the wall. Fire investigation revealed the cause of the fire to be water coming into contact with the aforementioned electrical outlet while the exterior of the house was being prepped for painting. No firefighters or building occupants were injured as a result of this fire.

Due to HIPAA we are prevented from disclosing an individual's protected health information (PHI). We may not release information regarding patient's names, DOB, address, SS# or medical status.



##