



NOTE:

1. SEE CITY STANDARD DETAIL 001 - GENERAL WATER NOTES.
2. ALL NEW VALVES SHALL BE RESILIENT WEDGE (RW) GATE VALVES PER STD. DETAIL 001.
3. SPOOLS MAY BE REQUIRED AS DIRECTED BY CITY ENGINEER.
4. FIRE HYDRANT LOCATION PER STD. DETAIL 020.

CITY OF SAN BUENAVENTURA

PUBLIC WORKS DEPARTMENT
ENGINEERING DIVISION

INTERSECTION WATER VALVE LOCATION

STD. DET. NO.
003

APPROVED BY: 
WATER GENERAL MANAGER

APPROVED BY: 
CITY ENGINEER R.C.E. 37064

DATE 7-7-16

SHEET
1 of 1