

NOTES:

1. THE UPPER END OF THE HOUSE CONNECTION SHALL BE CAPPED WITH STANDARD PLASTIC CAP.
2. TYPE "A" HOUSE CONNECTION SHALL BE CONSTRUCTED UNLESS OTHERWISE SHOWN ON THE PLANS.
3. CONTRACTOR SHALL MARK A 2" HIGH "S" 1/8" DEEP ON THE CURB FACE AT ALL SEWER LATERALS.
4. PIPE SHALL BE SDR-35 PVC SEWER PIPE OR APPROVED EQUAL.
5. IF PIPE IS INSTALLED BY TRENCHLESS METHOD, PIPE SHALL BE HDPE, SDR-17 OR APPROVED EQUAL.

CITY OF SAN BUENAVENTURA

PUBLIC WORKS DEPARTMENT
ENGINEERING DIVISION

STANDARD HOUSE CONNECTION TYPE "A"

STD. DET. NO.

204

APPROVED BY:


D. P. H.
WATER MANAGER

APPROVED BY:

R. L. R.
CITY ENGINEER R.C.E. 37064

DATE 7-19-12

SHEET
1 of 3



NOTES:

1. THE UPPER END OF THE HOUSE CONNECTION SHALL BE CAPPED WITH STANDARD PLASTIC CAP.
2. TYPE "A" HOUSE CONNECTION SHALL BE CONSTRUCTED UNLESS OTHERWISE SHOWN ON THE PLANS.
3. CONTRACTOR SHALL MARK A 2" HIGH "S" 1/8" DEEP ON THE CURB FACE AT SEWER LATERALS.
4. PIPE SHALL BE SDR-35 PVC SEWER PIPE, OR APPROVED EQUAL.
5. IF PIPE IS INSTALLED BY TRENCHLESS METHOD, PIPE SHALL BE HDPE, SDR-17 OR APPROVED EQUAL.

CITY OF SAN BUENAVENTURA

PUBLIC WORKS DEPARTMENT
ENGINEERING DIVISION

STANDARD HOUSE CONNECTION TYPE "B"

STD. DET. NO.

204

APPROVED BY:


[Signature]
WATER MANAGER

APPROVED BY:

[Signature]
CITY ENGINEER R.C.E. 37094

DATE 7-19-12

SHEET
2 of 3



NOTES:

1. THE UPPER END OF THE HOUSE CONNECTION SHALL BE CAPPED WITH STANDARD PLASTIC CAP.
2. TYPE "A" HOUSE CONNECTION SHALL BE CONSTRUCTED UNLESS OTHERWISE SHOWN ON THE PLANS.
3. CONTRACTOR SHALL MARK A 2" HIGH "S" 1/8" DEEP ON THE CURB FACE AT SEWER LATERALS.
4. PIPE SHALL BE SDR-35 PVC SEWER PIPE, OR APPROVED EQUAL.
5. IF PIPE IS INSTALLED BY TRENCHLESS METHOD, PIPE SHALL BE HDPE, SDR-17 OR APPROVED EQUAL.

CITY OF SAN BUENAVENTURA

PUBLIC WORKS DEPARTMENT
ENGINEERING DIVISION

STANDARD HOUSE CONNECTION TYPE "C"

STD. DET. NO.

204

APPROVED BY:

[Signature]
WATER MANAGER

APPROVED BY:

[Signature]
CITY ENGINEER R.C.E. 37064

DATE 7-19-12

SHEET
3 of 3