

## CITY OF VENTURA LOCAL LIMITS

PUBLIC WORKS DEPARTMENT **WASTEWATER DIVISION** 

Approved by:

Public Works Director

Date: 3-3/-/0

Effective Date: March 2, 2010 Revision:

## CITY OF VENTURA LOCAL LIMITS

This document contains the current approved local limits for those pollutants which have been established for the City of Ventura's POTW using standard procedures, calculations and methods acceptable to the State of California Regional Water Quality Control Board to protect against pass through, interference, protection of POTW employees, and adverse affects on wastewater residuals disposal.

This document is referred to and included in the City of Ventura's Sewer Use Ordinance (SUO) by reference in SUO Section 22.240.240. Section 22.240.240 of the SUO also details the point of application and revision of these local limits. The public works director may also impose mass limitations in addition to or in place of concentration-based limitations for local limits. The public works director may also develop specific Best Management Practices (BMPs) for individual pollutants, by ordinance or in non-domestic wastewater discharge permits or general permits, to implement local limits and the requirements of Section 22.240.210 of the SUO.

A copy of these approved local limits is available on request by any interested person at no charge at the office of the public works director.

Pollutant	Local Limit in milligrams per liter (PPM)
Arsenic	2.3
Boron	20.0
Cadmium	0.4
Chromium	16.0
Copper	17.0
Lead	0.8
Mercury	0.2
Nickel	22.0
Selenium	0.5
Silver	2.3
Sulfide	0.1
Zinc	14.0
Cyanide	2.7
Chloride	880.0
Sulfate	3660.0
Total Dissolved Solids (TDS)	4270.0
Fixed Dissolved Solids (FDS)	4270.0
Grease, oils and fats	600.0