
**RESIDENTIAL
BATHROOM REMODEL**

- Water line of type "L" copper
- Low flow fixtures
 - ≤ 1.28 gallons/flush toilet*
 - ≤ 1.8 gallon/minute single shower head at 80 psi**
 - ≤ 1.2 gallon/minute lavatory faucets at 60 psi
 - ≤ 0.125 gallon/flush urinal

*Note: The effective flush volume of dual flush toilets is defined as the composite, average flush volume of two reduced flushes and one full flush.

**Note: Multiple shower heads: combined flow rate of all shower heads and/or other shower outlets controlled by a single valve shall not exceed 1.8 gpm @ 80 psi or only one shower outlet is to be in operation at a time.

- Shower and tub-shower control valves to be pressure balance, thermostatic, or combination pressure/thermostatic mixing valve type.
- Bathtub and shower compartments shall be finished with nonabsorbent surface to a height of 72" above the floor.
- Shower compartment interior dimension shall have a minimum 1,024 sq. in. and capable of encompassing a 30 inch circle.
- Shower and/or tub enclosure door shall be tempered glass, safety glass or other listed and approved material.
- Glazing (glass) within 60" of tub or shower walking surface must be tempered, safety glass or other listed material.
- For indoor air quality and exhaust, see City of Ventura Cal Green Chapter 4 Residential Mandatory Measures Handout, section 4.506.1.
- Bathtub trap access of minimum 12" x 12" for concealed slip joint connections or indicate non-slip trap joint to be used.
- Water closet space – 30" wide by 24" deep clear are in front of water closet.
- All bathroom receptacles to be ground-fault circuit-interrupter protected. (GFCI)
- Lighting – permanently installed luminaries shall be of high efficacy type (LED or pin-base fluorescent) AND provide manual-on occupant sensor or vacancy sensor switch that meets California Energy Code requirements.

HOURS: Monday, Tuesday, Wednesday and Friday, 7:30 am to 5:00 pm
Thursday 9:00 am to 5:00 pm
Closed Alternate Fridays
Note: No Financial Transactions after 4:15 pm

LOCATION: Ventura City Hall, 501 Poli Street, Room 117

PHONE: 805-654-7869

MAILING ADDRESS: Ventura City Hall, 501 Poli Street, Room 117